

§ 141.551

requirements of §§141.551-141.553 . If your system uses slow sand or diatomaceous earth filtration you are not required to meet the combined filter effluent turbidity limits of subpart T, but you must continue to meet the combined filter effluent turbidity limits in §141.73.

§ 141.551 What strengthened combined filter effluent turbidity limits must my system meet?

Your system must meet two strengthened combined filter effluent turbidity limits.

(a) The first combined filter effluent turbidity limit is a “95th percentile” turbidity limit that your system must meet in at least 95 percent of the turbidity measurements taken each month. Measurements must continue to be taken as described in §141.74(a) and (c). Monthly reporting must be completed according to §141.570. The following table describes the required limits for specific filtration technologies.

If your system consists of * * *	Your 95th percentile turbidity value is * * *
(1) Conventional Filtration or Direct Filtration.	0.3 NTU.
(2) All other “Alternative” Filtration	A value determined by the State (no to exceed 1 NTU) based on the demonstration described in § 141.552.

(b) The second combined filter effluent turbidity limit is a “maximum” turbidity limit which your system may at no time exceed during the month. Measurements must continue to be taken as described in §141.74(a) and (c). Monthly reporting must be completed according to §141.570. The following table describes the required limits for specific filtration technologies.

If your system consists of * * *	Your maximum turbidity value is * * *
(1) Conventional Filtration or Direct Filtration.	1 NTU.
(2) All other “Alternative”	A value determined by the State (not to exceed 5 NTU) based on the demonstration as described in § 141.552.

§ 141.552 My system consists of “alternative filtration” and is required to conduct a demonstration—what is required of my system and how does the State establish my turbidity limits?

(a) If your system consists of alternative filtration (filtration other than slow sand filtration, diatomaceous earth filtration, conventional filtration, or direct filtration) you are required to conduct a demonstration (see tables in §141.551). Your system must demonstrate to the State, using pilot plant studies or other means, that your system’s filtration, in combination with disinfection treatment, consistently achieves:

- (1) 99 percent removal of *Cryptosporidium* oocysts;
- (2) 99.9 percent removal and/or inactivation of *Giardia lamblia* cysts; and
- (3) 99.99 percent removal and/or inactivation of viruses.

(b) [Reserved]

§ 141.553 My system practices lime softening—is there any special provision regarding my combined filter effluent?

If your system practices lime softening, you may acidify representative combined filter effluent turbidity samples prior to analysis using a protocol approved by the State.

INDIVIDUAL FILTER TURBIDITY REQUIREMENTS

§ 141.560 Is my system subject to individual filter turbidity requirements?

If your system is a subpart H system serving fewer than 10,000 people and utilizing conventional filtration or direct filtration, you must conduct continuous monitoring of turbidity for each individual filter at your system. The following requirements apply to continuous turbidity monitoring:

- (a) Monitoring must be conducted using an approved method in §141.74(a);
- (b) Calibration of turbidimeters must be conducted using procedures specified by the manufacturer;
- (c) Results of turbidity monitoring must be recorded at least every 15 minutes;
- (d) Monthly reporting must be completed according to §141.570; and

Environmental Protection Agency

§ 141.570

(e) Records must be maintained according to § 141.571.

§ 141.561 What happens if my system's turbidity monitoring equipment fails?

If there is a failure in the continuous turbidity monitoring equipment, your system must conduct grab sampling every four hours in lieu of continuous monitoring until the turbidimeter is back on-line. Your system has 14 days to resume continuous monitoring before a violation is incurred.

§ 141.562 My system only has two or fewer filters—is there any special provision regarding individual filter turbidity monitoring?

Yes, if your system only consists of two or fewer filters, you may conduct continuous monitoring of combined filter effluent turbidity in lieu of individual filter effluent turbidity monitoring. Continuous monitoring must meet the same requirements set forth in § 141.560(a) through (d) and § 141.561.

§ 141.563 What follow-up action is my system required to take based on continuous turbidity monitoring?

Follow-up action is required according to the following tables:

If * * *	Your system must * * *
(a) The turbidity of an individual filter (or the turbidity of combined filter effluent (CFE) for systems with 2 filters that monitor CFE in lieu of individual filters) exceeds 1.0 NTU in two consecutive recordings 15 minutes apart.	Report to the State by the 10th of the following month and include the filter number(s), corresponding date(s), turbidity value(s) which exceeded 1.0 NTU, and the cause (if known) for the exceedance(s).

If a system was required to report to the State * * *	Your system must * * *
(b) For three months in a row and turbidity exceeded 1.0 NTU in two consecutive recordings 15 minutes apart at the same filter (or CFE for systems with 2 filters that monitor CFE in lieu of individual filters).	Conduct a self-assessment of the filter(s) within 14 days of the day the filter exceeded 1.0 NTU in two consecutive measurements for the third straight month unless a CPE as specified in paragraph (c) of this section was required. Systems with 2 filters that monitor CFE in lieu of individual filters must conduct a self-assessment on both filters. The self-assessment must consist of at least the following components: assessment of filter performance; development of a filter profile; identification and prioritization of factors limiting filter performance; assessment of the applicability of corrections; and preparation of a filter self-assessment report. If a self-assessment is required, the date that it was triggered and the date that it was completed.
(c) For two months in a row and turbidity exceeded 2.0 BTU in 2 consecutive recordings 15 minutes apart at the same filter (or CFE for systems with 2 filters that monitor CFE in lieu of individual filters).	Arrange to have a comprehensive performance evaluation (CPE) conducted by the State or a third party approved by the State not later than 60 days following the day the filter exceeded 2.0 NTU in two consecutive measurements for the second straight month. If a CPE has been completed by the State or a third party approved by the State within the 12 prior months or the system and State are jointly participating in an ongoing Comprehensive Technical Assistance (CTA) project at the system, a new CPE is not required. If conducted, a CPE must be completed and submitted to the State no later than 120 days following the day the filter exceeded 2.0 NTU in two consecutive measurements for the second straight month.

§ 141.564 My system practices lime softening—is there any special provision regarding my individual filter turbidity monitoring?

If your system utilizes lime softening, you may apply to the State for alternative turbidity exceedance levels for the levels specified in the table in § 141.563. You must be able to demonstrate to the State that higher turbidity levels are due to lime carryover only, and not due to degraded filter performance.

REPORTING AND RECORDKEEPING REQUIREMENTS

§ 141.570 What does subpart T require that my system report to the State?

This subpart T requires your system to report several items to the State. The following table describes the items